Panasonic

No.: C-SB453H6B-00-GGS-0

APPROVAL SHEET SPECIFICATIONS OF HERMETIC SCROLL COMPRESSOR

CODE	809 861 86
MODEL	C-SB453H6B

\triangle						
\triangle						
\triangle						
\triangle						
\triangle						
NO.	DATE	PAGE	REVISION DETAILS PAPCDL SIG		PAPCDL SIGNED	CLIENT SIGNED
REVISION RECORD						
USER: MANUFACTURER: Panasonic Appliances Compressor (Dalian) Co., Ltd.						
LEADER	PURCHAS MANAGE		TECHNICAL MANAGER	APPROVED	CHECKED	SUBMITTED

File No: C-SB453H6B-00-GGS-0

Section 1. General Specifications

			•
	Content	Unit	Specification
Compressor Mode	el (Code)	_	C-SB453H6B (809 861 86)
Туре		_	Hermetic Scroll Compressor
Application		_	High Back Pressure
Evap. Temp. Ran	ge	°C (°F)	-15~12 (5~54)
Compressor Cool	ing Type	_	Natural Cooling
	Phase	_	3
Power Source	Rated Voltage	V	208-230
	Rated Frequency	Hz	60
Voltage Range	•	V	187-253
Weight (Including	Oil)	kg (lb)	39.5(87.1)
Refrigerant		_	R22
Oil Type		_	Mineral Oil(SAY56T or Equivalent)
Oil Charge		ml (fl oz)	1700 (57.5)
Displacement		cm ³ (in ³) /rev	100.0(6.10)
	Motor Type	_	3-PH Induction Motor
	Number of Poles	_	2
	Electrical Insulation	Class	E
Motor	Nominal Revolution	min ⁻¹	3490
WOO	Locked Rotor Ampere	А	153
	NAVI 11 D 1 1		U-V 0.483
	Winding Resistance [at 25°C (77°F)]	Ω	U-W 0.483
	[]		V-W 0.495
Connection Tube	Suction Line (O.D.)	mm (in)	22.2 (0.875)
Connection rube	Discharge Line (O.D.)	mm (in)	12.7 (0.500)
Compressor Surfa	ace Paint	_	Black Paint

Notes

- 1 Voltage range is applied at standard rating conditions.
- 2 Motor specifications in the table are the average values for your reference.
- 3 (): All units with parentheses are reference values.

Expiration of Specification

Expiration of this specification shall be effected until issuing a notice with indication of the expiration date from the issued date. In case of improvement or elimination of this specification, it shall be handled by the revision record based on agreement between both sides.

File No:

C-SB453H6B-00-GGS-0

Section 2. Performance Warranty

2.1 Performance

Power Source (3PH)	Hz	60	60	Remark
i ower source (Si Ti)	V	208	230	
Capacity	W	21,300	21,500	±5%
	(BTU/hr)	72,676	73,358	reference
Input Power	W	6,550	6,600	±5%
Current	Α	20.50	20.40	±5%

Standard Rating Conditions

Condensing Temp.	°C (°F)	54.4(130)
Evaporating Temp.	°C (°F)	7.2(45)
Suction Gas Temp.	°C (°F)	18.3(65)
Liquid Temp.	°C (°F)	46.1(115)
Ambient Temp.	°C (°F)	35.0(95)

2.2 Sound Level

Power Source (3PH)	Hz	60
rower source (SrTI)	V	230
Sound Level	dB(A)	65.0Max.

Notes

- 1 The operating conditions are the same as 2.1.
- 2 MIC location is the distance of 1m (3.28feet) from the compressor.
- 3 Sound Level is an average sound pressure level in four directions.

2.3 Minimum Starting Voltage

Power Source (3PH)	Hz	60
Minimum Starting Voltage	V	166
Conditions		
Compressor Temp	°C (°F)	10~60(50~140)

Compressor Temp.	°C (°F)	10~60(50~140)
Ambient Temp.	°C (°F)	10~40(50~105)
High Pressure	MPa(G)/psig	2.0(290)
Low Pressure	MPa(G)/psig	0.5(72)

2.4 Others

Content		Unit	Specification
Dooign Proceure	L.P. S.	MPa(G)/psig	1.6(232)
Design Pressure	H. P. S.	MPa(G)/psig	3.0(435)
Insulation Resistance		ΜΩ	100 (without refrigerant)
Dielectric Strength		V	1500 (1 minute)
Residual Moisture		mg	300

Note:

1. The insulation resistance be measured with a DC500V megohm tester.

File No:

C-SB453H6B-00-GGS-0

Section 3. Standard Accessories

3.1 Accessories List

Parts Name	Qty	Parts code	Revision No.	Note
Terminal Box Cover	1	A-0101-DSB	0	Installed on Compressor
Terminal Box Clip	1	A-0201-DSB	0	Installed on Compressor
Eyelet Rub Lead Wire	1	A-0301-DSB	0	Installed on Compressor
Mounting Grommet	4	M-0101-DSB	0	Included with Compressor
Mounting Sleeve	4	M-0201-DSB	0	Included with Compressor
Screw Special	1	B-0101-DSB	0	Installed on Compressor

3.2 The Drawing for Reference

Parts Name	Parts Code	Revision No.
Compressor Outline Drawing	D-0101-DSB	0
Mounting Parts Listing	M-5101-DSB	0
Packing Dimensions	D-0202-DSB	0
Wiring Diagram	E-0914-DSB	0

3. 3 Inernal Motor Protector (in compressor)

Parts Name	Specification		
	Trip Temprature	160±5℃	
Inernal Motor Protector	Reset Temprature	70±10 ℃	
	Trip Current	114A / 3~10s	


File No: C-SB453H6B-00-GGS-0

Section 4. Compressor Protection

4.1 Protection Required but not Included with compressor

Protection Device	Items	Specifications		
Reversal Defensible Relay	Features	To protect the compressor from reverse rotation		
Reversal Deletisible Relay	Rated Voltage	AC208-230V		
Crankcase Heater	Rated Power	35 Watts		
	Mounting Position	Located within 100mm(4 in)from the compressor shell		
Discharge Thermostat	Trip Temperature	130±5°C(266 ±10 °F)		
	Reset Temperature	95±11°C (205 ± 20 °F)		
High Pressure Switch	Setting	Cut-out seting no higher than 3.0Mpa(G)		
Low Pressure Switch	Setting	Cut-out seting no lower than 0.03Mpa(G)		


4.2 Position of the Protection and Refrigerant Charging



Section 5. Operating Envelope

Suction Gas Superheat: 11.1K

Refrigerant: R22



Section 6. Application Standard & Limit

The following requirements apply to vertical type hermetic scroll compressors:

Standard: Applicable to ordinary conditions in Japan JIS B8616 or standards relative to JIS B8616, such as standard rating conditions, maximum operating conditions, low temperature conditions, etc.

Limit: Applicable to transitional brief period of time, such as start-up and beginning of defrost mode.

No.	Item	Standard	Limit	Note		
1	Refrigerant	R22(Meet the standar				
2	Evaporating Temp.	-15~12°C(5∼54 °F)	Comp. Suction Pressure			
		0.20~0.62MPa(G)(29∼90psig)				
3	Condensing Temp.	30~65°C(86∼149°F)	68℃(155 °F)	Comp.Design Pressure(High)		
3		1.09~2.60MPa(G)(158~377psig)	3.0MPa(G) (435psig)			
4	Compression Ratio	2~6				
5	Winding Temp.	115℃(240 °F) Max.	115℃(240 °F) Max. 125℃(257 °F)			
	Shell Bottom Temp.	90℃(194				
6		Evaporating Temp	Operating			
		Ambient Temp	Not Operating			
_	Discharge Gas Temp.	C-SB:130°C (266°F) Max.		Temp. within 100mm(4in) of the discharge fitting.		
7		115℃(240 °F) Max.	C-SC:135℃(275°F) Max.	Temp. inside of the well pipe on the top of compressor		
8	Suction Gas Temp.	Superheat: 5K(10 °F)Min.	No excessive noise	It should meet the requirement of item 5, 6, 7 and 14 within 30cm of the suction fitting.		
9	Running Voltage	Within ±10% of	Voltage at compressor terminals.			
10	Starting Voltage	Three Phase Models: 859	Voltage at compressor terminals.			
10		Single Phase Models: 90°				
	On/Off Cycling	On Period: Until the oil level return	For at least 7 minutes - on/3 minutes-off is recommendable.			
11		Off Period: Until balance of high ar				
12	Refrigerant Charge	oil/refrigera	Specific gravity of the Oil:0.92.			
13	Life Time	200,00				
14	Minimum Oil Level	C-SB: Center of the lower bearing				
		C-SC:No less than 70%				
15	Abnormal Pressure Rise/Drop	Pressure Rise: 3.0M	By high pressure switch			
		Pressure Drop: 0.03	By low pressure switch			
16	System Moisture Level	200рр				
17	System Uncondensable Gas	1 Vol.	24 hrs. after vacuuming: 1.01kPa Max.			
	Level	Residuai Oxygen 0.1 Vol.% Max.				
18	Tilt	5° De				

Operation beyond the above limits must be approved by Panasonic Appliances Compressor (Dalian) Co., Ltd.

(G): Gauge Pressure

Notes

- 1 Installation should be completed within 15 minutes after removing the rubber plugs.
- 2 Do not use the compressor to compress air.
- 3 Do not energize the compressor under vacuumed conditon.
- 4 Evacuation and Refrigerant charge: Evacuate internal section in the refrigeration system from high and low pressure sides and charge liquid refrigerant from condenser outlet side. Additional charge shall be done with gas condition from low side.
- 5 Do not tilt over the compressor while carrying it.
- 6 Do not remove the paint.
- 7 Crankcase heater is required when the oil sump temperature is too low to meet the requirement of item 6 on page7.
- 8 Voltage fluctuation between compressor terminals, during operation, shall be within 2% of the rated voltage.
- 9 Do not operate compressor in reverse rotational direction.
- 10 Suction strainers are recommended for all applications.

11 Copper Piping Stress Start/Shutdown 34.32 N/mm² Max.

Run 12.26 N/mm² Max.


Section 7. Selection of Electrical Wire

Voltage drop may occur due to the large current draw during compressor starting.


We recommend selecting the wire size from the table below.

7.1 Type of Unit

7.1.1 Window & Commercial Type Unit



7.1.2 Split Type(Separate Type)




7.2 Size Table of Electrical Wire


	Size of electrical wire (mm²)								
Starting current (A)	Remark ①	Remark③ (heat-resistance Temperature: 120°C(248°F) min.)							
	5m max.	10m max.	15m max.	20m max.	30m max.	50m max.	1m max.		
20max.	2.0	2.0	2.0	3.5	5.5	8.0	2.0		
30max.	†	↑	3.5	5.5	†	14.0	†		
40max.	†	3.5	5.5	↑	8.0	1	†		
50max.	†	↑	†	8.0	14.0	22.0	↑		
60max.	↑	5.5	†	↑	↑	↑	↑		
70max.	3.5	↑	8.0	14.0	↑	↑	3.5		
80max.	↑	↑	†	↑	22.0	30.0	↑		
90max.	↑	↑	14.0	↑	↑	↑	↑		
100max.	↑	8.0	†	↑	↑	38.0	↑		
110max.	†	↑	†	↑	↑	↑	†		
120max.	5.5	↑	†	22.0	30.0	↑	↑		
140max.	†	14.0	†	↑	†	50.0	5.5		
160max.	†	↑	22.0	↑	†	1	↑		
180max.	†	↑	†	↑	38.0	60.0	8.0		
200max.	8.0	↑	†	30.0	↑	1	<u> </u>		
220max.	↑	↑	†	↑	50.0	80.0	<u></u>		
240max.	↑	<u> </u>	†	<u></u>	<u> </u>	<u> </u>	14.0		


7.3 Caution of Ground

The internal motor protector does not protect the compressor against all possible conditions.

Please be sure that the system utilizes the ground connection when installed in the field.








Part Code

D-0202-DSB

Name

Packing Dimensions



Part Code E-0914-DSB Name Wiring Diagram